



We help ideas meet the real world

# Compliance Statement

No. 2015-406

## Unscreened Permanent Link, Class E

### Company

GIGANET NETWORKING  
SOLUTIONS LTD  
9 De Montfort Street  
Leicester LE1 7GE  
United Kingdom

### Permanent Link Identification (2 connector model)

#### Horizontal cable :

Giganet Cat. 6 UTP 23 AWG, GN-C6X4-UTP-PVC, GN-C6X4-UTP-LSOH

#### Wall Outlet:

Giganet Cat. 6 UTP, GN-C6-KS-180-01, GN-C6-LJ6C, GN-C6-5025-UK

#### Patch Panel:

Giganet Cat.6 UTP, GN-C6-PP-XX (X:24 or48)

### Generic cabling standards - Class E Permanent Link requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- EN 50173-1:2011
- EN 50173-2:2007, including amendment A1:2010
- ANSI/TIA-568-C.2:2009

### Technical report

DELTA-T211028-03, DANAK-19/15511

### EC Cabling product ID

5229

### CS valid until

1 August 2016

This product has been tested by DELTA EC Cabling Group and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 27 August 2015

Lars Lindskov Pedersen  
Test Manager

Claude Videt  
Project Manager

### DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
[www.madebydelta.com/cable](http://www.madebydelta.com/cable)

